



District Level Water Analysis Laboratory
Office OF Executive Engineer, Khand Karyalay
Uttar Pradesh Jal Nigam, (Rural)
Fatehpur (212601)



TC-12419

Test Report (Water)

Report N C:	C/07/2025/39	Date:	25/07/2025		
URL Number	1241925000000039F				
Customer details					
Office Name and Address:	Abhay Pratap Singh (APS) International School Khaga Fatehpur		Customer Mob.	8810759513	
Ref Letter No & Date:	-----				
Basic details of sample					
District:	Fatehpur	Block:	Airayan		
Gram Panchayat / Town :	Khaga	Village/ City:	Khaga		
Habitation:	Khaga	Location:	GT Road Yuvraj Nager Khaga Fatehpur		
Water Source:	Tube well	Sample no:	01		
Quantity of Sample:	2.0 Litter	Date of S.C.:	23/07/2025		
Receiving Date:	23/07/2025	S. Collector Name	Mahendra		
Sample Depositor:	Mahendra	Analysis Completion Date:	24/07/2025		
Analysis Start Date:	24/07/2025				
Environmental Condition					
Temperature	25±3 ⁰ C	Relative Humidity	50 ± 15 %		
Technical Date of Analysis					
S.No.	Analysed Parameters	Observed Value	Specified Values as Per BIS 10500:2012		Ref. Method Of Analysis
			Acceptable Limit	Permissible	
			4	5	6
1	2	3	4	5	6
1	PH*	7.61	6.5	8.5	IS 3025 (Part 11): 2022 (Electrometric Method)
2	Turbidity (NTU)*	1.08	1	5	IS 3025 (Part 10):2023
3	Chloride (Mg/L)*	42	250	1000	IS 3025 (Part 32): 2019
4	Total Alkalinity (Mg/L)*	344	200	600	Is 3025 (Part 23): 2023
5	Total Hardness (Mg /L)*	320	200	600	Is 3025 (Part 21): 2023
6	Fluoride	0.98	1	1.5	Is 3025 (Part 60): 2019 (Electro. Chem. Probe Meth.
7	Calcium (as Ca)*	128	75 mg/L	200 mg/L	IS 3025 (Part 40): 2024
8	Magnesium (as Mg)*	30	30 mg/L	100 mg/L	IS 3025 (Part 46): 2023
9	TDS	662	500	2000	IS 3025 (Part 16): 2023
10	IRON (AS Fe)	0.1	1	No Relaxation	IS 3025 (Part 53): 2024
11	Sulphates	58	75	200	IS 3025 (Part 24/Sec 1): 2022
12	Nitrate	16	45	No Relaxation	IS 3025 (Part 34) : 2019
Note	1 . (*) Indicates parameters that are NABL accredited.				
	2. this test results related to the sample tested above.				
	3. the report shall not be reproduced in full without approval of authority.				
	4. this is the end of the report.				
Report Prepared by		Report Analysis by		Authorized Signatory	
Anuj Kumar		Sandeep Kumar		In-Charge	

End of Test Report

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 26/07/2025

It is certified that an inspection team headed by Devhuti Pandey (Executive Officer)

(Name of Officers with designation) from Govt. of State (U.P.) PHED

inspected the Abhay Pratap Singh Inter National School, Khaga, Fatehpur

(Name & Address of the school) on 24/07/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. C/07/2025/39 dated 25/07/2025

of District Level Water Analysis Lab (PHED Lab) certified that the

Abhay Pratap Singh Inter National School, Khaga, Ftp (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 26/07/2028

Signature with Seal:

Name

Designation

Name & Address of the Office / Department

वैद्यहूती पाण्डेय

अधिकांशी अधिकारी

नगर पंचायत, खगा, फतेहपुर

Executive Officer

Nagar Panchayat, Khaga

To

Abhay Pratap Singh Inter National School

C.T. Road, Khaga, Fatehpur

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies